



NOTES:

1. ONLY ONE TRANSITION IN PIPE MATERIALS ALLOWED BETWEEN ANY TWO MANHOLES.
2. FOR PVC TO D.I.P., AND D.I.P. TO D.I.P. CONNECTIONS, LONG BODY D.I.M.J. SLEEVES SHALL BE USED.

STANDARD DETAIL	
Metropolitan Sewerage District of Buncombe County, North Carolina	
FLEXIBLE PIPE COUPLING FOR CONNECTIONS TO VCP ONLY	
DATE APPROVED: MARCH 2017	2.01 - 03