



TRENCH WIDTH
 THE MINIMUM TRENCH WIDTH SHALL BE THE NOMINAL PIPE DIAMETER PLUS 24", EXCEPT THAT THE MINIMUM TRENCH WIDTH SHALL NOT BE LESS THAN 48" IN ANY CASE

Maximum Depth of Cover for Vitrified Clay Pipe in Each Bedding Class					
Pipe Size (in)	Type 1	Type 2	Type 3	Type 4	Type 5
6	16	22	28	30	30
8	13	18	23	27	28
10	12	16	20	24	25
12	11	15	18	22	23
15	9	13	17	19	20
18	9	12	16	18	19
21	9	12	16	18	19
24	9	12	16	18	19

STANDARD DETAIL

Metropolitan Sewerage District
 of Buncombe County, North Carolina

**TYPICAL TRENCH DETAIL FOR
 VITRIFIED CLAY PIPE**

DATE APPROVED: MARCH 2017 2.02 - 01