



GENERAL NOTES:

1. SEE PIPING AND INSTRUMENTATION DIAGRAM, DRAWING B-4486-104A, FOR EQUIPMENT TAG (XXX) REFERENCE.
2. SEE ELECTRICAL SCHEMATIC AND ENCLOSURE DRAWINGS B-4486-102A AND B-4486-103A FOR WIRING.
3. ALL ANALOG SIGNAL WIRING IS TO BE RUN IN SEPARATE CONDUIT AND RACEWAYS FROM THAT OF SYSTEM HIGH VOLTAGE CONTROL WIRING.
4. CONTROL INSTRUMENTATION POWER SUPPLY IS 24 VDC UNLESS OTHERWISE NOTED.

[illegible]